

- ✕ TREE TO BE REMOVED
- ⊗ TREE TO BE REMOVED/REPLACED PER RESOURCE MANAGEMENT DISTRICT PERMIT PLN# 041-101-290
- ⊙ REPLACED TREE LOCATION PER LANDSCAPE PLANS
- ⊖ EXISTING TREE TO REMAIN, PROTECT IN PLACE

Show actual tree dripline for County to determine impact of grading on tree. Limits of grading should remain outside of tree protection buffer.

Limits of grading should remain outside of tree protection buffer.

Show actual line of tree canopy/dripline. Proposed tree protection needs to extend to the riparian tree's dripline.

No individual tree fencing required in riparian area that will be fenced off

TEMPORARY CONSTRUCTION CHAINLINK FENCE WITH POSTS EMBED INTO GROUND. PROVIDE SIGN INDICATING THE FENCED AREA IS "RESTRICTED" AS AN "ENVIRONMENTALLY SENSITIVE AREA" AND ALL CONSTRUCTION ACTIVITIES, PERSONNEL, AND OPERATIONAL DISTURBANCES ARE PROHIBITED.

PROTECT EX TREES TO REMAIN (TYP) 6 C11.60

CONSTRUCTION/STAGING LIMITS (TYP)

NOTE: SEE SHEET C11.91 FOR GEOTECHNICAL MITIGATION

