

REQUEST FOR INFORMATION  
FOR  
COUNTY OF SAN MATEO

LISTED BELOW ARE THE QUESTIONS (Q) SUBMITTED BY  
POTENTIAL BIDDERS FOR THE

COYOTE POINT MARINA MAINTENANCE DREDGING  
AND PILE REPLACEMENT PROJECT

COUNTY PROJECT NO. OD516  
PROJECT FILE NO. E5061

THE COUNTY OF SAN MATEO DEPARTMENT OF PUBLIC WORKS  
HAS PROVIDED RESPONSES (R) TO THE QUESTIONS BELOW

*Responses R1, R2, and R3 provided on 04/6/2022*

Q1. Do we get a bid bond based on all items being awarded or just schedule A?

*R1. The contract requires a bid bond for all Items covered in all Schedules.*

Q2. The BCDC permit requires a current eelgrass survey to determine if measures such as turbidity curtains need to be employed, and where they would be placed. Has this survey been conducted, and are turbidity curtains needed for the project?

*R2. The survey will be performed by the County and must be performed 30 days prior to dredging. The requirement for turbidity curtains will be determined by the agencies only if eelgrass is detected within the dredging area or the 250 meter buffer zone. At this time, turbidity curtains and light monitoring are not required for the dredging work. Please note that no eelgrass was found within the dredging area or 250 meter buffer zone during the 2017 survey.*

Q3. Just to clarify: digging beneath docks and headways is permitted, but not required?

*R3. Correct. Digging beneath docks and headways is permitted, but not required, with the exception of the main headwalk of Docks 27, 28 and 29 where it is required to Required Elevation of -4 feet MLLW. See the plans and specifications (Section 22) for details.*